



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15162-48-4217**  
State Number  
**27852**

EQUIPMENT INSPECTED

State Number: <b>27852</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: SCHINDLER	Speed: 40
Landings: 2	Installed: 05/10/2011	Rope Size:
Volts: 230	Complied:	Entrances: 1
OWNER	OCCUPANT	
WATERBORO VILLAGE MGMT	WATERWAY COVE CLUBHOUSE	
1140 308 KILDAIRE FARM ROAD	100 WATERWAY DRIVE SW	
CARY, NC, 27512	OCEAN ISLE, NC, 28469	

INSPECTION INFORMATION

Inspection Date 06/11/2015	Type Inspection Routine	Certificate Status Not Issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	----------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.11.2.2.2	Perform the annual no load safety test
N/A	PARTIAL INSPECTION: [UNIT NOT RUNNING]

Items must be corrected by: 07/11/2015

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: SCOTT COOK

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WATERBORO VILLAGE MGMT  
1140 308 KILDAIRE FARM ROAD  
CARY, NC, 27512