



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15163-38-578
State Number
24950

EQUIPMENT INSPECTED

State Number: **24950** Type of Unit: Passenger Floor to Floor: 1 to 3
Capacity: 3500 Manuf: THYSSEN KRUPP Speed: 125
Landings: 2 Installed: 06/19/2007 Rope Size: 0
Volts: 480 Complied: Entrances: 1

OWNER OCCUPANT
CITY OF CHARLOTTE CATS FACILITIES CATS SOUTH BOULEVARD LIGHT RAIL FACILITY
600 E. 4TH ST 3200 S. BLVD
CHARLOTTE, NC, 28202 CHARLOTE, NC, 28217

INSPECTION INFORMATION

Inspection Date 06/12/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 38 - Raborn	County MECKLENBURG	60 F
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------------	------

VIOLATIONS

8.6.4.15 Emergency operation of signaling devices, lighting, communication, and ventilation, shall be maintained.(PHONE FINAL NOTICE 10 DAYS TO CORRECT)

Items must be corrected by: 06/22/2015

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainance with current codes.

Violations pointed out to: Brent Roland 704.432.4765

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CITY OF CHARLOTTE CATS FACILITIES
600 E. 4TH ST
CHARLOTTE, NC, 28202