N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15166-36-197
State Number
16229

EQUIPMENT INSPECTED

State Number: **16229**
Capacity: 2500
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 03/07/1996
Complied: 03/07/1996

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
UNIVERSAL FOREST PRODUCTS
5631 SOUTH NC 62
BURLINGTON, NC, 27215

OCCUPANT
UNIVERSAL FOREST PRODUCTS
5631 SOUTH NC 62
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/15/2015	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: KENDAL FOX 336-229-5156 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
UNIVERSAL FOREST PRODUCTS
5631 SOUTH NC 62
BURLINGTON, NC, 27215