N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15173-36-4590
State Number
23035

EQUIPMENT INSPECTED

State Number: **23035**	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: SCHINDLER	Speed: 100
Landings: 3	Installed: 08/16/2005	Rope Size:
Volts: 480	Complied: 08/16/2005	Entrances: 1

OWNER	OCCUPANT
ALAMANCE COMMUNITY COLLEGE	ALAMANCE COMMUNITY COLLEGE LEARNING CENT
1247 JIMMY KERR ROAD	1247 JIMMY KERR RD
GRAHAM, NC, 27235	GRAHAM, NC, 27235

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/22/2015	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Eric (336) 578-2002 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to: ALAMANCE COMMUNITY COLLEGE
1247 JIMMY KERR ROAD
GRAHAM, NC, 27235