



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15176-60-3785
State Number
20202

EQUIPMENT INSPECTED

State Number: 20202	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 04/18/2002	Rope Size: 0
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
BEACH MOUNTAIN CLUB	BEACH MOUNTAIN CLUB	
114 CLUB HOUSE ROAD	114 CLUB HOUSE ROAD	
BEACH MOUNTAIN, NC, 28604	BEACH MOUNTAIN, NC, 28604	

INSPECTION INFORMATION

Inspection Date 06/25/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 60 - Kircher	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

8.11.3.2.1 Provide the annual relief valve and system pressure test.

Items must be corrected by: 07/05/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Beach mountain

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BEACH MOUNTAIN CLUB
114 CLUB HOUSE ROAD
BEACH MOUNTAIN, NC, 28604