



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15180-59-3057
State Number
18294

EQUIPMENT INSPECTED

State Number: 18294	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 135
Landings: 3	Installed: 08/27/1999	Rope Size:
Volts: 208	Complied: 05/11/2001	Entrances: 1
OWNER	OCCUPANT	
ARDENWOODS LLC	ARDENWOODS A RETIREMENT COMMUNITY	
2400 APPALACHIAN BLVD	2400 APPALACHIAN BLVD	
ARDEN, NC, 28704	ARDEN, NC, 28704	

INSPECTION INFORMATION

Inspection Date 06/29/2015	Type Inspection Compliance	Certificate Status Prev Issued	Inspector 59 - Cannon	County BUNCOMBE	11 A
-------------------------------	-------------------------------	-----------------------------------	--------------------------	--------------------	------

VIOLATIONS

note John said the vavle had been changed. Asheville Elevator has the service and did the work.

Items must be corrected by: 07/29/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: John/Arden Woods Maintenance

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARDENWOODS LLC
2400 APPALACHIAN BLVD
ARDEN, NC, 28704