



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15190-16-2224
State Number
N7.7

EQUIPMENT INSPECTED

State Number: N7.7	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 06/05/1975	Rope Size: 1/2
Volts: 220	Complied: 06/05/1975	Entrances: 2
OWNER	OCCUPANT	
DOWN ON MAIN ST	DOWN ON MAINSTREET RESTAURANT	
FRANCIS NOBLES	107 MAIN ST	
NEW BERN, NC, 28562	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 07/09/2015	Type Inspection Not Inspected	Certificate Status Not Issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------------	----------------------------------	-------------------------	--------------------

7

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Could not get in Bldg.

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DOWN ON MAIN ST
FRANCIS NOBLES
NEW BERN, NC, 28562