



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15190-16-2419
State Number
N7.16

EQUIPMENT INSPECTED

State Number: N7.16	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 1200	Manuf: WESTBROOK	Speed: 100
Landings: 4	Installed: 01/24/1978	Rope Size: 5/8
Volts: 220	Complied: 01/24/1978	Entrances: 1

OWNER

JAMES EVERETT DUNCAN JR
106 W. MAIN ST.
WASHINGTON, NC, 27889

OCCUPANT

OASIS HAIR SALON
106 W MAIN ST
WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date 07/09/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

- 8.6.4.10.1[b] For winding drum machines located below or beside the hoistway, with 1:1 roping the babbitt rope socket fastening shall be resocketed or relocated on the rope for other type of fastenings every 2 years
- 8.6.4.20 Provide the five year full load test.

Items must be corrected by: 08/08/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: James Duncan / Owner

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

JAMES EVERETT DUNCAN JR
106 W. MAIN ST.
WASHINGTON, NC, 27889