



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15198-48-026
State Number
20134

EQUIPMENT INSPECTED

State Number: 20134	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: SCHINDLER	Speed: 100
Landings: 2	Installed: 06/27/2002	Rope Size: .
Volts: 480	Complied: 06/27/2002	Entrances: 1
OWNER	OCCUPANT	
BLADEN COUNTY BOARD OF EDUCATION	EAST BLADEN HIGH SCHOOL	
PO BOX 2519	HWY 87E	
ELIZABETHTOWN, NC, 28337	ELIZABETHTOWN, NC, 28337	

INSPECTION INFORMATION

Inspection Date 07/17/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

VIOLATIONS

8.11.2.2.2	Perform the annual no load safety test
n/a	Loose hand rail in car

Items must be corrected by: 08/16/2015

Elevator Name: # I

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Greg

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BLADEN COUNTY BOARD OF EDUCATION
PO BOX 2519
ELIZABETHTOWN, NC, 28337