



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15203-16-1278
State Number
24436

EQUIPMENT INSPECTED

State Number: 24436	Type of Unit: Passenger	Floor to Floor: P to 3
Capacity: 2500	Manuf: TKE	Speed: 125
Landings: 4	Installed: 01/09/2007	Rope Size: 0
Volts: 230	Complied: 01/09/2007	Entrances: 2
OWNER	OCCUPANT	
DAY BEACON HOA	DAY BEACON	
PO BOX 1303	326 E WATER STREET	
MANTEO, NC, 27954	BELLHAVEN, NC, 27810	

INSPECTION INFORMATION

Inspection Date 07/22/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

n/a No violations found

Elevator Name: A

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Staton / Property Manager

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DAY BEACON HOA
PO BOX 1303
MANTEO, NC, 27954