



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15204-7-527
State Number
11397

EQUIPMENT INSPECTED

State Number: 11397	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 08/22/1985	Rope Size:
Volts: 480	Complied: 08/22/1985	Entrances: 1
OWNER	OCCUPANT	
ALLEGHANY COUNTY	ALLEGHANY HIGH SCHOOL	
85 PEACHTREE ST	404 TROJAN AVE	
SPARTA, NC, 28675	SPARTA, NC, 28675	

INSPECTION INFORMATION

Inspection Date 07/23/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 7 - Hoffman	County ALLEGHANY
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

3

VIOLATIONS

NONE

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: ALLEGHANY CO. 336-372-4345

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALLEGHANY COUNTY
85 PEACHTREE ST
SPARTA, NC, 28675