



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15208-16-5267
State Number
25676

EQUIPMENT INSPECTED

State Number: 25676	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 06/16/2008	Rope Size: 0
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
SELECT BANK AND TRUST	GEORGE TOWNE OFFICE BLDG	
155 N MARKET ST	155 N MARKET ST	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 07/27/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

2.14.7.1.3 Put the in car emergency light in working order.

Items must be corrected by: 08/26/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Sonny / Bank Manager

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SELECT BANK AND TRUST
155 N MARKET ST
WASHINGTON, NC, 27889