



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15209-36-0157**  
State Number  
**26097**

EQUIPMENT INSPECTED

State Number: <b>26097</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: SCHINDLER	Speed: 100
Landings: 3	Installed: 05/13/2008	Rope Size:
Volts: 208	Complied: 05/13/2008	Entrances: 1

OWNER

ETHAN POINTE APARTMENTS  
2978 ETHAN POINTE DRIVE  
BURLINGTON, NC, 27215

OCCUPANT

ETHAN POINTE APARTMENTS  
1176 KIRKPATRICK RD  
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 07/28/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machine rooms and machinery spaces.  
8.6.4.7.1 Clean the elevator pit.

Items must be corrected by: 08/27/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: KAREN VEZINA 336-584-3337

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ETHAN POINTE APARTMENTS  
2978 ETHAN POINTE DRIVE  
BURLINGTON, NC, 27215