



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15210-8-0750
State Number
8131

EQUIPMENT INSPECTED

State Number: 8131	Type of Unit: Freight	Floor to Floor: 1 to 4
Capacity: 4000	Manuf: SOUTHERN	Speed: 100
Landings: 4	Installed: 04/22/1975	Rope Size:
Volts: 0	Complied: 04/28/1975	Entrances: 1
OWNER	OCCUPANT	
UNIVERSAL FIBER SYSTEMS LLC	PREMIERE FIBERS INC	
PO BOX 436	HWY 52 N	
ANSONVILLE, NC, 28007	ANSONVILLE, NC, 28007	

INSPECTION INFORMATION

Inspection Date 07/29/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County ANSON
-------------------------------	----------------------------	---------------------------------	-------------------------	-----------------

4

VIOLATIONS

8.11.1.2	PERFORM ANNUAL PRESSURE TEST
8.6.4.13	REPAIR BOTTOM FLOOR DOOR LOCK

Items must be corrected by: 07/29/2015

Elevator Name: SMALL FREIGHT ELEV

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: SURESH SUNDARAMOORTHY

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

UNIVERSAL FIBER SYSTEMS LLC
PO BOX 436
ANSONVILLE, NC, 28007