



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15211-36-5032
State Number
14972

EQUIPMENT INSPECTED

State Number: 14972	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 11/19/1993	Rope Size:
Volts: 460	Complied: 12/08/1993	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE COUNTY	CRIMINAL COURTS BLDG	
124 W ELM ST	W ELM ST	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 07/30/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

none found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Chris Rollins (336) 570-6700

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE COUNTY
124 W ELM ST
GRAHAM, NC, 27253