



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15211-48-3324
State Number
21154

EQUIPMENT INSPECTED

State Number: 21154	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 2	Installed: 09/24/2002	Rope Size: 0
Volts: 480	Complied: 09/24/2002	Entrances: 1
OWNER	OCCUPANT	
BRUNSWICK CO. BOARD OF EDUC.	W. BRUNSWICK HIGH SCHOOL	
35 REFREEDOM DRIVE	550 WHITEVILLE RD., NW	
BOLIVIA, NC, 28422	SHALLOTTE, NC, 28470	

INSPECTION INFORMATION

Inspection Date 07/30/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s). [SAME AS LAST YR.]

Items must be corrected by: 08/29/2015

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: RETHA GAUSE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK CO. BOARD OF EDUC.
35 REFREEDOM DRIVE
BOLIVIA, NC, 28422