



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15216-48-1488
State Number
14616

EQUIPMENT INSPECTED

State Number: 14616	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 12000	Manuf: OTIS	Speed: 75
Landings: 3	Installed: 08/17/1992	Rope Size:
Volts: 480	Complied: 06/16/2003	Entrances: 1
OWNER	OCCUPANT	
SMITHFIELD PACKING	CAROLINA FOOD PROCESSORS	
1911 S. CHURCH ST.	HWY 87S	
SMITHFIELD, VA, 23430	TAR HEEL, NC, 28392	

INSPECTION INFORMATION

Inspection Date 08/04/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

VIOLATIONS

2.27.3.1	Put the Phase I fire service feature in proper working order.
N/A	REPAIR OR REPLACE HALL BUTTON PANEL ON 1ST FL.
N/A	REPLACE BAD SHAFT DR. GUIDE RAILS [1ST. FL.]
N/A	REPAIR CAR BACK WALL
N/A	REPLACE CAR STATION PANEL

Items must be corrected by: 09/03/2015

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DENNIS PARKS

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SMITHFIELD PACKING
1911 S. CHURCH ST.
SMITHFIELD, VA, 23430