N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15216-48-4225
State Number
14615

EQUIPMENT INSPECTED

State Number: **14615**
Capacity: 2500
Landings: 2
Volts: 480

Type of Unit: Passenger
Manuf: OTIS
Installed: 09/17/1992
Complied: 10/01/1992

Floor to Floor: 1 to 2
Speed: 125
Rope Size:
Entrances: 1

OWNER
SMITHFIELD PACKING
1911 S. CHURCH ST.
SMITHFIELD, VA, 23430

OCCUPANT
CAROLINA FOOD PROCESSOR
NC HWY. 87S
TARHEEL, NC, 28392

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
08/04/2015	Routine	Re-issued	48 - Martin	BLADEN

9

VIOLATIONS

8.6.4.9 Clean the elevator car top.

8.11.1.6 Provide a metal with test date, the requirement number requiring the test, and the name of the person or firm performing the test inside the machine room for all Categories 3, 5 tests for electric elevators and 1,3, 5 tests for hydraulic elevators

2.14.7.1.3 Put the in car emergency light in working order.

2.27.1.1.2 Put the in car emergency telephone in proper working order. [REPAIR DOOR]

N/A PROVIDE MISSING CEILING PANEL IN CAR

Items must be corrected by: 09/03/2015

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: DENNIS PARKS

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
SMITHFIELD PACKING
1911 S. CHURCH ST.
SMITHFIELD, VA, 23430