N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15217-48-4344
State Number
19671

EQUIPMENT INSPECTED

State Number: **19671**
Capacity: 3500
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 12/07/2000
Complied: 12/07/2000

Floor to Floor: 1 to 3
Speed: 150
Rope Size:
Entrances: 1

OWNER
SEA TRAIL CORPORATION
279 CLUBHOUSE RD
SUNSET BEACH, NC, 28468

OCCUPANT
SEA TRAIL - CAHMPION #35
137 AVIAN DR
SUNSET BEACH, NC, 28468

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
08/05/2015	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 09/04/2015

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: WILLIAM FLOYD

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
SEA TRAIL CORPORATION
279 CLUBHOUSE RD
SUNSET BEACH, NC, 28468