N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15218-48-4445
State Number
23517

EQUIPMENT INSPECTED

State Number: **23517**	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 3	Installed: 12/15/2005	Rope Size: .
Volts: 208	Complied: 12/15/2005	Entrances: 1

OWNER	OCCUPANT
SEA TRAIL CORPORATION	SEA TRAIL CHAMPION BLDG #39
279 CLUBHOUSE RD.	142 AVIAN DR
SUNSET BEACH, NC, 28468	SUSNET BEACH, NC, 28468

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
08/06/2015	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

2.7.5.1	Put the machine room lights in working order.
2.27.1.1.2	Put the in car emergency telephone in proper working order.

Items must be corrected by: 09/05/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: WILLIAM FLOYD

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
SEA TRAIL CORPORATION
279 CLUBHOUSE RD.
SUNSET BEACH, NC, 28468