



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15229-16-1954**  
State Number  
**6865**

EQUIPMENT INSPECTED

|                                      |                                       |                        |
|--------------------------------------|---------------------------------------|------------------------|
| State Number: <b>6865</b>            | Type of Unit: Passenger               | Floor to Floor: 1 to 2 |
| Capacity: 8000                       | Manuf: SOUTHERN                       | Speed: 50              |
| Landings: 2                          | Installed: 07/28/1980                 | Rope Size: 0           |
| Volts: 440                           | Complied: 06/14/1991                  | Entrances: 2           |
| OWNER                                | OCCUPANT                              |                        |
| CLARCOR ENGINE MOBILE SOLUTIONS CORP | CLARCOR ENGINE MOBILE SOLUTIONS CORP. |                        |
| PO BOX 1105                          | 230 CLARKS NECK ROAD                  |                        |
| WASHINGTON, NC, 27889                | WASHINGTON, NC, 27889                 |                        |

INSPECTION INFORMATION

|                               |                            |                                 |                         |                    |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|
| Inspection Date<br>08/17/2015 | Type Inspection<br>Routine | Certificate Status<br>Re-issued | Inspector<br>16 - Moore | County<br>BEAUFORT |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|

7

VIOLATIONS

2.14.7.1.3 Put the in car emergency light in working order.

Items must be corrected by: 09/16/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Security

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CLARCOR ENGINE MOBILE SOLUTIONS CORP  
PO BOX 1105  
WASHINGTON, NC, 27889