## NCDOL NCDOL NA Department of John

## N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

## INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927 Report Number 15229-48-055 State Number 15684

			EQUIPMENT INSPECTED			
State Number: 15684 Type of Unit		Passenger	Floor to Floor:	Floor to Floor: G to 2		
Capacity: 2100 Manuf: OTI		Speed: 125				
Landings: 3 Installed: 10		0/1995	Rope Size:			
Volts: 208 Complied: 1		30/1995	Entrances: 1			
OWNER			OCCUPANT			
CASWLL PARTNERSHIP			OCEAN GREENS BLDG #2			
OCEAN GREENS LANE		55-58 FOX FIRE LN.				
CASWELL BEACH, NC, 28465			CASWELL BEACH, NC, 28465			
		II.	NSPECTION INFORMATION			
Inspection Date 08/17/2015		Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK	
			VIOLATIONS			
.15.2	Replace t	cracked, worn, or missing car guides.				
.6.4.8.1	Clean the	e elevator machine room.				
	7.1 Clean the elevator pit.					

Items must be corrected by: 09/16/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE Inspector \_\_\_\_\_

To make changes to the invoice mailing address please call: 919-733-0372

THIS IS NOT AN INVOICE

An invoice will be mailed to:

CASWLL PARTNERSHIP OCEAN GREENS LANE CASWELL BEACH, NC, 28465