



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15231-36-4384
State Number
H710

EQUIPMENT INSPECTED

State Number: H710	Type of Unit: Hand Lift	Floor to Floor: G to 1
Capacity: 450	Manuf: ACCESS	Speed: 20
Landings: 2	Installed: 06/26/1996	Rope Size: 0
Volts: 110	Complied: 06/26/1996	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE - BURLINGTON SCHOOL SYSTEM	WILLIAMS HIGH SCHOOL	
1712 VAUGHN RD	1307 S CHURCH ST	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 08/19/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

2.1.1.3 Take steps to repair metal step going into handicap lift on the first floor

Items must be corrected by: 09/18/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: 'Caroline_Bolton@abss.k12.nc.us'

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE - BURLINGTON SCHOOL SYSTEM
1712 VAUGHN RD
BURLINGTON, NC, 27215