



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15231-48-5999
State Number
23724

EQUIPMENT INSPECTED

State Number: 23724	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 50
Landings: 4	Installed: 03/10/2006	Rope Size: 0
Volts: 230	Complied: 03/10/2006	Entrances: 1
OWNER OCEAN WALK HOA C/O GO PROPERTY MGMT-G OWEN WILMINGTON, NC, 28405		OCCUPANT OCEAN WALK CONDO #1 105 SE 58TH STREET OAK ISLAND, NC, 28465

INSPECTION INFORMATION

Inspection Date 08/19/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

- 2.2.2.4 Put the sump pump in proper working order.
- 8.6.4.7.4 Remove the water from the pit floor.
- 8.6.4.8.1 Clean the elevator machine room.
- 8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).
- 2.14.7.1.4 Put the car top light in working order.
- 8.6.4.9 Clean the elevator car top.
- 2.27.3.1 Put the Phase I fire service feature in proper working order. [INOPERATIVE]
- 2.27.1.1.2 Put the in car emergency telephone in proper working order. [NO LOCATION]

Items must be corrected by: 09/18/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OCEAN WALK HOA
C/O GO PROPERTY MGMT-G OWEN
WILMINGTON, NC, 28405