



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
www.nclabor.com/elevator.htm  
919-707-7927

Report Number  
**15232-16-3277**  
State Number  
**25683**

EQUIPMENT INSPECTED

State Number: <b>25683</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 4	Installed: 07/31/2008	Rope Size: 0
Volts: 208	Complied: 07/31/2008	Entrances: 1
OWNER	OCCUPANT	
MOSS LANDING OWNERS ASSOC	MOSS LANDING	
PO BOX 59	401 MOSS WAY	
GREENVILLE, NC, 27835	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 08/20/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

2.14.7.1.3 Put the in car emergency light in working order.

Items must be corrected by: 09/19/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Sue Smith/ Manager

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MOSS LANDING OWNERS ASSOC  
PO BOX 59  
GREENVILLE, NC, 27835