



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15232-48-2436**  
State Number  
**24260**

### EQUIPMENT INSPECTED

State Number: <b>24260</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 50
Landings: 4	Installed: 11/07/2006	Rope Size: 0
Volts: 240	Complied: 11/07/2006	Entrances: 1
OWNER OCEAN WALK HOA C/O GO PROPERTY MGMT-G OWEN WILMINGTON, NC, 28405		OCCUPANT OCEANWALK CONDOS #7 105 SE 58TH STREET OAK ISLAND, NC, 28465

### INSPECTION INFORMATION

Inspection Date 08/20/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

### VIOLATIONS

8.6.5.5.2	Empty the drain bucket in the pit. [ BUCKET TURNED OVER ]
2.27.3.1	Put the Phase I fire service feature in proper working order. [ INOPERATIVE ]
2.27.1.1.2	Put the in car emergency telephone in proper working order. [ NO LOCATION ]

Items must be corrected by: 09/19/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OCEAN WALK HOA  
C/O GO PROPERTY MGMT-G OWEN  
WILMINGTON, NC, 28405