



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15232-48-3928
State Number
24257

EQUIPMENT INSPECTED

State Number: 24257	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 50
Landings: 4	Installed: 08/29/2006	Rope Size: 0
Volts: 240	Complied:	Entrances: 1
OWNER	OCCUPANT	
OCEAN WALK HOA	OCEAN WALK CONDOS #4	
C/O GO PROPERTY MGMT-G OWEN	105 SE 58TH STREET	
WILMINGTON, NC, 28405	OAK ISLAND, NC, 28465	

INSPECTION INFORMATION

Inspection Date 08/20/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.3.1	Put the Phase I fire service feature in proper working order. [NO FIRE HAT LIGHT IN CAR]
8.6.4.9	Clean the elevator car top.
2.14.7.1.4	Put the car top light in working order.
2.27.1.1.2	Put the in car emergency telephone in proper working order.
N/A	PUT COVER BACK ON LEVELING UNIT ON TOP OF CAR
N/A	REPLACE DAMAGED MOTOR ROOM DOOR

Items must be corrected by: 09/19/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OCEAN WALK HOA
C/O GO PROPERTY MGMT-G OWEN
WILMINGTON, NC, 28405