



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15239-4-256
State Number
8962

EQUIPMENT INSPECTED

State Number: 8962	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 06/02/1977	Rope Size: 0
Volts: 220	Complied: 06/02/1977	Entrances: 1
OWNER	OCCUPANT	
ESEECOLA LODGE	ESEECOLA LODGE CLUBHOUSE	
P.O BOX 99	83 ROSEBORO ROAD	
LINVILLE, NC, 28646	LINVILLE, NC, 28646	

INSPECTION INFORMATION

Inspection Date 08/27/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 60 - Kircher	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

8.6.4.7.4 Remove the oil soaked rags from the pit floor.

Items must be corrected by: 09/26/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Eseecola Lodge # 828-733-4311

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ESEECOLA LODGE
P.O BOX 99
LINVILLE, NC, 28646