



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15239-4-4922**  
State Number  
**6201**

#### EQUIPMENT INSPECTED

State Number: <b>6201</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 1500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 08/13/1969	Rope Size: 0
Volts: 208	Complied: 11/20/2000	Entrances: 1

OWNER  
LEES MCRAE COLLEGE  
P.O. BOX 128  
BANNER ELK, NC, 28604

OCCUPANT  
LEES MCRAE COLLEGE  
150 BUENA VISTA WAY  
BANNER ELK, NC, 28604

#### INSPECTION INFORMATION

Inspection Date 08/27/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 60 - Kircher	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

#### VIOLATIONS

- 8.6.4.7.4 Remove the 5 gal bucket from the pit.
- 8.11.1.6 Provide the missing metal tag in the machine room with all pertinent information on the test performed. (Category 3 & 5 elevators; 1,3,5 hydraulic elevators) Periodic Test Tag with pressure test date.

Items must be corrected by: 09/26/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Lees Mcrae College # 828-898-8770

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LEES MCRAE COLLEGE  
P.O. BOX 128  
BANNER ELK, NC, 28604