



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15243-48-4314
State Number
28841

EQUIPMENT INSPECTED

State Number: 28841	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: TKE	Speed: 110
Landings: 3	Installed: 07/29/2013	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
WESTGATE SENOIR APTS	WESTGATE SENOIR LIVING ELEV 2	
9200 OCEANGATE PLAZA EXT	9200 OCEANGATE PLAZA EXT	
LELAND, NC, 28541	LELAND, NC, 28541	

INSPECTION INFORMATION

Inspection Date 08/31/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JADA TAYLOR

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WESTGATE SENOIR APTS
9200 OCEANGATE PLAZA EXT
LELAND, NC, 28541