N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15244-48-0040
State Number
23851

EQUIPMENT INSPECTED

State Number: **23851**
Capacity: 3000
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 06/02/2006
Complied: 06/02/2006

Floor to Floor: 1 to 3
Speed: 150
Rope Size: 0
Entrances: 1

OWNER
COMMUNITY ASSOCIATION MANAGEMENT
PO BOX 8126
OCEAN ISLE BEACH, NC, 28469

OCCUPANT
COLONY 11 BLDG 7
908 RESORT CIRCLE
SUNSET BEACH, NC, 28465

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
09/01/2015	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

8.6.4.8.1 Clean the elevator machine room.

Items must be corrected by: 10/01/2015

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
COMMUNITY ASSOCIATION MANAGEMENT
PO BOX 8126
OCEAN ISLE BEACH, NC, 28469