



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15266-17-3330
State Number
13203

EQUIPMENT INSPECTED

State Number: **13203**

Capacity: 2000

Landings: 3

Volts: 480

Type of Unit: Passenger

Manuf: ASHEVILLE

Installed: 02/01/1990

Complied: 02/01/1990

Floor to Floor: G to 3

Speed: 100

Rope Size:

Entrances: 1

OWNER

ARBORETUM BUILDING

100 FREDRICK LAW OLMSTEAD WAY

ASHEVILLE, NC, 28806

OCCUPANT

ARBORETUM BUILDING

WESLEY BRANCH RD

ASHEVILLE, NC, 28806

INSPECTION INFORMATION

Inspection Date
09/23/2015

Type Inspection
Routine

Certificate Status
Re-issued

Inspector
17 - White

County
BUNCOMBE

11 A

VIOLATIONS

note

no violations

Items must be corrected by: 09/23/2015

Elevator Name: 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: office 828-665-2492

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ARBORETUM BUILDING
100 FREDRICK LAW OLMSTEAD WAY
ASHEVILLE, NC, 28806