



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15288-48-2659**  
State Number  
**29324**

EQUIPMENT INSPECTED

State Number: <b>29324</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: ANER CRESC	Speed: 100
Landings: 2	Installed: 08/28/2015	Rope Size:
Volts: 208	Complied:	Entrances: 2
OWNER	OCCUPANT	
JIM FISH	BRUNSWICK SENIOR CONDOS	
3620 EXPRESS DRIVE	3620 EXPRESS DRIVE	
SHALLOTTE, NC, 28470	SHALLOTTE, NC, 28470	

INSPECTION INFORMATION

Inspection Date 10/15/2015	Type Inspection Compliance	Certificate Status Not Issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	-------------------------------	----------------------------------	--------------------------	---------------------

10

VIOLATIONS

N/A FAILED DUE TO: FIRE RECALL - CAULKING IN HOISTWAY - REPAIR MOTOR ROOM DOOR TO CLOSE AND LOCK ON ITS OWN

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DANNY

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

JIM FISH  
3620 EXPRESS DRIVE  
SHALLOTTE, NC, 28470