



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15296-8-3764
State Number
613

EQUIPMENT INSPECTED

State Number: 613	Type of Unit: Freight	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: MONARCH	Speed: 50
Landings: 2	Installed: 12/21/1945	Rope Size: 1/2
Volts: 220	Complied: 06/25/2004	Entrances: 1
OWNER	OCCUPANT	
WILLIAM IVEY	SOUTHERN ANTIQUES & POTTERY/ CLOCK SHOP	
118 S CHURCH ST	118 S CHURCH ST	
ASHEBORO, NC, 27203	ASHEBORO, NC, 27203	

INSPECTION INFORMATION

Inspection Date 10/23/2015	Type Inspection Not Inspected	Certificate Status Not Issued	Inspector 8 - Burris	County RANDOLPH
-------------------------------	----------------------------------	----------------------------------	-------------------------	--------------------

76

VIOLATIONS

. Building Closed

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: .

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WILLIAM IVEY
118 S CHURCH ST
ASHEBORO, NC, 27203