



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15302-8-1857
State Number
5631

EQUIPMENT INSPECTED

State Number: 5631	Type of Unit: Passenger	Floor to Floor: B to 2
Capacity: 1000	Manuf: WESTBROOK	Speed: 100
Landings: 3	Installed: 10/14/1966	Rope Size:
Volts: 208	Complied: 10/24/1966	Entrances: 1
OWNER	OCCUPANT	
RANDOLPH COUNTY	OLD RANDOLPH COUNTY COURTHOUSE	
2212 S FAYETTEVILLE ST	145 WORTH ST	
ASHEBORO, NC, 27205	ASHEBORO, NC, 27204	

INSPECTION INFORMATION

Inspection Date 10/29/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County RANDOLPH
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

76

VIOLATIONS

8.6.4 ELEVATOR FLOOR LEVELS NOT THE SAME EACH TIME THE ELEVATOR MAKES A RUN. I RECOMMEND OLD BRASS VALVES BE REPLACED WITH UNIT VALVE SO FLOOR LEVELS CAN BE ACHIEVED

Elevator Name: VISITOR ELEVATOR

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JAMES CHRISCOE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

RANDOLPH COUNTY
2212 S FAYETTEVILLE ST
ASHEBORO, NC, 27205