

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
www.nclabor.com/elevator.htm  
919-807-2770

Report Number <b>15306-8-4949</b> State Number <b>N4.6</b>
---------------------------------------------------------------------

EQUIPMENT INSPECTED

State Number: <b>N4.6</b>	Type of Unit: Freight	Floor to Floor: B to 3
Capacity: 0	Manuf: WESTBROOK	Speed: 50
Landings: 4	Installed: 01/01/1978	Rope Size: 5/8
Volts: 220	Complied: 08/29/1978	Entrances: 1
OWNER	OCCUPANT	
H W LITTLE & CO	H W LITTLE & CO	
109 S. GREEN ST.	109 S. GREEN ST.	
WADESBORO, NC, 28170	WADESBORO, NC, 28170	

INSPECTION INFORMATION

Inspection Date 11/02/2015	Type Inspection Routine	Certificate Status Not Issued	Inspector 8 - Burris	County ANSON
-------------------------------	----------------------------	----------------------------------	-------------------------	-----------------

4

VIOLATIONS

8.11.1.2	PERFORM SAFTY TEST
NCAC	CERTIFICATE NOT REISSUED CALL FOR REINSPECTION WHEN REPAIRED
8.6	CLEAN ALL SAFTY COMPONENTS FOR PROPER OPERATION & AJUST SAFTY
8.6	AJUST BULL ROPE FOR PROPER FLOOR LEVELS
8.6	REPLACE BRAKE PAD

Items must be corrected by: 12/02/2015

Elevator Name: FREIGHT ELEVATOR

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: CARLY LITTLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

H W LITTLE & CO  
109 S. GREEN ST.  
WADESBORO, NC, 28170