



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15314-36-1185
State Number
6830

EQUIPMENT INSPECTED

| | | |
|---------------------------|-------------------------|------------------------|
| State Number: 6830 | Type of Unit: Passenger | Floor to Floor: 1 to 2 |
| Capacity: 1500 | Manuf: STHERN | Speed: 100 |
| Landings: 2 | Installed: 10/21/1970 | Rope Size: |
| Volts: 220 | Complied: 10/21/1970 | Entrances: 1 |

OWNER

JERRY T WARREN & ASSOC
900 N MAIN STREET
RANDLEMAN, NC, 27317

OCCUPANT

JERRY T WARREN & ASSOC
900 N MAIN STREET
RANDLEMAN, NC, 27317

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|---------------------------|--------------------|
| Inspection Date 11/10/2015 | Type Inspection Routine | Certificate Status Re-issued | Inspector 36 - Kirkman | County RANDOLPH |
|-------------------------------|----------------------------|---------------------------------|---------------------------|--------------------|

76

VIOLATIONS

- 8.6.10.2 Access Keys. Keys required for access, operation, inspection, maintenance, repair, and emergency access shall be made available only to personnel in the assigned security level.
- 8.6 keep area clear in front of elevator

Items must be corrected by: 12/10/2015

Elevator Name: PASSENGER ELEV

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JERRY WARREN 336.498.6554

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

JERRY T WARREN & ASSOC
900 N MAIN STREET
RANDLEMAN, NC, 27317