



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**15314-48-1683**  
State Number  
**29982**

EQUIPMENT INSPECTED

State Number: <b>29982</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 3500	Manuf: SCHINDLER	Speed: 125
Landings: 4	Installed: 06/02/2015	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
BECKER GORGAN GROUP INC	DOLPHIN SHORES AT HOLDEN BEACH	
3205 RANDALL PKWY STE 211	2252 DOLPHIN SHORES BLVD SW	
WILMINGTON, NC, 28403	SUPPLY, NC, 28462	

INSPECTION INFORMATION

Inspection Date 11/10/2015	Type Inspection New	Certificate Status Not Issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	------------------------	----------------------------------	--------------------------	---------------------

10

VIOLATIONS

N/A UNIT FAILED DUE TO FIRE RECALL

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DAVE LARKINS

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BECKER GORGAN GROUP INC  
3205 RANDALL PKWY STE 211  
WILMINGTON, NC, 28403