



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15320-48-0898
State Number
16529

EQUIPMENT INSPECTED

State Number: 16529	Type of Unit: Special	Floor to Floor: 1 to 4
Capacity: 650	Manuf: SIDNEY	Speed: 96
Landings: 4	Installed: 04/28/1997	Rope Size: 1/2
Volts: 440	Complied: 04/30/1997	Entrances: 1
OWNER	OCCUPANT	
MURPHY BROWN	MURPHY BROWN	
DBA SMITHFIELD HOG PRODUCTION	DBA SMITHFIELD HOG PRODUCTION	
BLADENSBORO, NC, 28320	BLADENSBORO, NC, 28320	

INSPECTION INFORMATION

Inspection Date 11/16/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BLADEN
-------------------------------	----------------------------	---------------------------------	--------------------------	------------------

9

VIOLATIONS

8.6.4.7.1	Clean the elevator hoistway.
N/A	SHORTEN CWT. ROPES [CWT. HITTING SPRINGS IN PIT]

Items must be corrected by: 12/16/2015

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: BILLY SANDLIN

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MURPHY BROWN
DBA SMITHFIELD HOG PRODUCTION
BLADENSBORO, NC, 28320