



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15322-48-4620
State Number
24062

EQUIPMENT INSPECTED

State Number: 24062	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: SCHINDLER, HYD	Speed: 100
Landings: 3	Installed: 11/14/2006	Rope Size: 0
Volts: 208	Complied: 11/14/2006	Entrances: 1

OWNER

PALMS AT LONG BEY - 2000
1240 EAGLECREST DRIVE
STANLEY, NC, 28164

OCCUPANT

THE PALMS @ LONG BAY
140 SE 59 STREET
OAK ISLAND, NC, 28645

INSPECTION INFORMATION

Inspection Date 11/18/2015	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.2.2.4	Install the cover on the sump pump.
8.6.4.7.1	Clean the elevator pit.

Items must be corrected by: 12/18/2015

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

PALMS AT LONG BEY - 2000
1240 EAGLECREST DRIVE
STANLEY, NC, 28164