N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
15343-7-5926
State Number
27737

EQUIPMENT INSPECTED

State Number: **27737**
Capacity: 2500
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: TKE
Installed: 09/07/2011
Complied: 09/07/2011

Floor to Floor: 1 to 3
Speed: 100
Rope Size:
Entrances: 2

OWNER
MIDWAY BAPTIST CHURCH
1670 MT JEFFERSON ROAD
WEST JEFFERSON, NC, 28694

OCCUPANT
MIDWAY BAPTIST CHURCH
1670 MT JEFFERSON ROAD
WEST JEFFERSON, NC, 28640

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
12/09/2015	Routine	Re-issued	7 - Hoffman	ASHE

5

VIOLATIONS

8.11.3.2.1 PERFORM THE ANNUAL RELIEF VALVE TEST

Items must be corrected by: 01/08/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: MIDWAY BAPTIST CH. 336-246-2012 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
MIDWAY BAPTIST CHURCH
1670 MT JEFFERSON ROAD
WEST JEFFERSON, NC, 28694