



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16005-48-0921
State Number
17610

EQUIPMENT INSPECTED

State Number: 17610	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 06/30/1998	Rope Size:
Volts: 208	Complied: 04/06/2000	Entrances: 2
OWNER	OCCUPANT	
SEA TRAIL CORP	JONES / BRYD CLUBHOUSE	
211 CLUBHOUSE RD	211 CLUBHOUSE RD	
SUNSET BEACH, NC, 28468	SUNSET BEACH, NC, 28468	

INSPECTION INFORMATION

Inspection Date 01/05/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.14.1.4.5	Put the in car stop switch in proper working order. [NO ALARM BELL]
2.2.5.1	Put the pit lights in proper working order.
8.6.4.7.1	Clean the elevator pit.
N/A	REPAIR CAB FLOOR

Items must be corrected by: 02/04/2016

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: LISA

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SEA TRAIL CORP
211 CLUBHOUSE RD
SUNSET BEACH, NC, 28468