



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16005-48-2149
State Number
H1522

EQUIPMENT INSPECTED

State Number: H1522	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: THYSSEN KRUPP	Speed: 12
Landings: 2	Installed: 09/01/2004	Rope Size:
Volts: 115	Complied: 09/01/2004	Entrances: 2
OWNER	OCCUPANT	
COUNTY OF BRUNSWICK	BRUNSWICK COUNTY LIBRARY	
PO BOX 249	1040 CALABASH RD.	
BOLIVIA, NC, 28422	CALABASH, NC, 28467	

INSPECTION INFORMATION

Inspection Date 01/05/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

5.1.21.1	Put the in car alarm bell in working order.
2.14.1.4.5	Put the in car stop switch in proper working order. [NO ALARM BELL].

Items must be corrected by: 02/04/2016

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Christi Iffergan

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

COUNTY OF BRUNSWICK
PO BOX 249
BOLIVIA, NC, 28422