



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16029-16-3576**  
State Number  
**22271**

### EQUIPMENT INSPECTED

State Number: <b>22271</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: TKE	Speed: 50
Landings: 3	Installed: 12/17/2009	Rope Size: 0
Volts: 240	Complied:	Entrances: 1
OWNER	OCCUPANT	
MR MARK GRAY	WASHINGTON DOWNTOWN OFB	
108 N ELM STREET	158 E MAIN STREET	
GREENSBORO, NC, 27401	WASHINGTON, NC, 27889	

### INSPECTION INFORMATION

Inspection Date 01/29/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

### VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 02/28/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: No One There

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MR MARK GRAY  
108 N ELM STREET  
GREENSBORO, NC, 27401