



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16034-48-2920
State Number
27273

EQUIPMENT INSPECTED

State Number: 27273	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 4500	Manuf: OTIS	Speed: 125
Landings: 4	Installed: 04/08/2010	Rope Size:
Volts: 480	Complied:	Entrances: 1
OWNER	OCCUPANT	
BRUNSWICK NOVANT MEDICAL CENTER	BRUNSWICK NOVANT MEDICAL CENTER	
240 HOSPITAL DRIVE NE	240 HOSPITAL DRIVE NE	
BOLIVIA, NC, 28422	BOLIVIA, NC, 28422	

INSPECTION INFORMATION

Inspection Date 02/03/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.3.1 Put the Phase I fire service feature in proper working order. [NO ALARM]

Items must be corrected by: 03/04/2016

Elevator Name: # 4

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: J. Melcher

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK NOVANT MEDICAL CENTER
240 HOSPITAL DRIVE NE
BOLIVIA, NC, 28422