



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16036-17-0162
State Number
16690

EQUIPMENT INSPECTED

State Number: 16690	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: AEC	Speed: 100
Landings: 3	Installed: 06/24/1997	Rope Size:
Volts: 208	Complied: 06/24/1997	Entrances: 1
OWNER		OCCUPANT
AB TECHNICAL COMMUNITY COLLEGE		AB TECHNICAL/HEMLOCK
340 VICTORIA ROAD		340 VICTORIA ROAD
ASHEVILLE, NC, 28801		ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 02/05/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.4.7.4	Take steps to eliminate the accumulation of water on the pit floor and remove same.
8.11	Seal over speed valve.

Items must be corrected by: 03/06/2016

Elevator Name: hemlock

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Randy

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AB TECHNICAL COMMUNITY COLLEGE
340 VICTORIA ROAD
ASHEVILLE, NC, 28801