



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16036-17-5414**  
State Number  
**13037**

EQUIPMENT INSPECTED

State Number: <b>13037</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 05/16/1989	Rope Size:
Volts: 240	Complied: 05/25/1989	Entrances: 1
OWNER	OCCUPANT	
A B TECHNICAL COLLEGE IND ED BLDG	A B TECHNICAL COLLEGE/DOGWOOD	
340 VICTORIA RD	340 VICTORIA RD	
ASHEVILLE, NC, 28801	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 02/05/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 02/15/2016

Elevator Name: dogwood

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Randy

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

A B TECHNICAL COLLEGE IND ED BLDG  
340 VICTORIA RD  
ASHEVILLE, NC, 28801