



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16036-17-5818
State Number
21935

EQUIPMENT INSPECTED

State Number: 21935	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 3500	Manuf: SCHINDLER	Speed: 125
Landings: 3	Installed: 11/10/2003	Rope Size: 0
Volts: 480	Complied: 11/10/2003	Entrances: 1

OWNER

ASHEVILLE BUNCOMBE TECH
340 VICTORIA RD
ASHEVILLE, NC, 28801

OCCUPANT

ASHEVILLE BUNCOMBE TECH/BALSAM
COMPUTER TECH BLDG
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 02/05/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

note no violations

Items must be corrected by: 02/05/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Randy

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE BUNCOMBE TECH
340 VICTORIA RD
ASHEVILLE, NC, 28801