



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16041-36-2493
State Number
27992

EQUIPMENT INSPECTED

State Number: 27992	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 5000	Manuf: OTIS	Speed: 100
Landings: 4	Installed: 12/16/2011	Rope Size:
Volts: 480	Complied: 12/16/2011	Entrances: 1
OWNER	OCCUPANT	
LANDMARK GROUP	MEBANE MILLS LOFTS	
401 N HERITAGE STREET	301 W WASHINGTON STREET	
WINSTON SALEM, NC, 27101	MEBANE, NC, 27302	

INSPECTION INFORMATION

Inspection Date 02/10/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 03/11/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Amy Younts 919-568-9176

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LANDMARK GROUP
401 N HERITAGE STREET
WINSTON SALEM, NC, 27101