



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16048-36-5173
State Number
24933

EQUIPMENT INSPECTED

State Number: 24933	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 80
Landings: 2	Installed: 09/10/2007	Rope Size:
Volts: 480	Complied: 09/10/2007	Entrances: 1
OWNER	OCCUPANT	
R K HOSPITALITY GROUP	COLONNADES DINING (LOBBY)	
100 WOODLAKE PARKWAY	193 DALTON MCMICHAEL DR	
KINGS MOUNTAIN, NC, 28086	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 02/17/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

none found

Elevator Name: COLLANADES lobby

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Bob Willis 336.278.2000

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

R K HOSPITALITY GROUP
100 WOODLAKE PARKWAY
KINGS MOUNTAIN, NC, 28086